



National Floor Safety Institute
 1845 Precinct Line Road, Suite 212
 Hurst, TX 76054
 Phone: (817) 749-1700
 info@nfsi.org

January 25, 2024

Roy Bowman
 Curecrete Distribution, Inc.
 1203 W Spring Creek Place
 Springville, UT 84663

Dear Roy Bowman:

Congratulations! The products listed below are now recertified. Retesting was completed on January 15, 2024, under the NFSI B101.1 Test Method for Measuring Wet SCOF of Common Hard-Surface Floor Materials and the NFSI B101.3 Test Method for Measuring Wet DCOF of Common Hard-Surface Floor Materials. Please review the results below.

Product Name	B101.1 SCOF	Logo Use	B101.3 DCOF	Logo Use	Original Certification Date	Expiration Date
Ashford Formula	0.65	High-Traction	0.54	High-Traction	12/13/2017	1/25/2027
RetroPlate - 800 grit	0.67	High-Traction	0.49	High-Traction	12/18/2017	1/25/2027
RetroPlate - 1500 grit	0.66	High-Traction	0.45	High-Traction	12/18/2017	1/25/2027

Products may only bear the NFSI Certified Logo that corresponds with the above results. Please let us know if you have any questions. Thank you for supporting the product certification process with the NFSI.



This logo is available for products originally tested to the appropriate NFSI standard and manufactured in identical form as when originally certified by NFSI, and/or products that undergo retesting with the appropriate NFSI standard and meet the current standards High-Traction threshold.

This logo is available for products that undergo retesting with the appropriate NFSI standard and meet the current standards Moderate-Traction threshold.

Sincerely,

Russell J. Kendzior
 President