



December 20, 2017

Mr. Dave Hoyt
Director of Technical Service
Curecrete Distribution, Inc.
1203 W Spring Creek Place
Springville, UT 84663

Dear Mr. Hoyt:

Congratulations! The **RetroPlate** product submitted for Phase 2 Testing passed and is certified as providing "High-Traction".

We completed testing on December 18, 2017 under the ANSI/NFSI B101.1-2009 Test Method for Measuring Wet SCOF of Common Hard-Surface Floor Materials and under the ANSI/NFSI B101.3-2012 Test Method for Measuring Wet DCOF of Common Hard-Surface Floor Materials. Our on-site examination revealed Static Coefficient of Friction (SCOF) values greater than a 0.60 and Dynamic Coefficient of Frictions (DCOF) values greater than 0.42; therefore, the product passed our Phase 2 level of certification for both SCOF and DCOF. Your certification is good through December 18, 2020.

An electronic version of the NFSI Certified logo may be obtained to which you are granted permission to attach to the **RetroPlate** product label, sales literature, website, etc.



Again, congratulations and thank you for submitting your product to the NFSI.

Sincerely,

A handwritten signature in blue ink, appearing to read "Russell J. Kendzior", is written over a horizontal blue line.

Russell J. Kendzior
President



The National Floor Safety Institute
P.O. Box 92607
Southlake, TX 76092
Phone: (817) 749-1700
info@nfsi.org

December 1, 2020

Mr. Dave Hoyt
Curecrete Distribution, Inc.
1203 W Spring Creek Place
Springville, UT 84663

Dear Mr. Hoyt:

This letter confirms the renewal of your NFSI Product Certification listed below. Please note the NFSI Certified Logo changed as of October 2012 and products must bear the new NFSI Certified Logo below.



Product Names	Original Certification Date	Expiration Date
Ashford Formula	12/13/2017	12/13/2023
RetroPlate	12/18/2017	12/18/2023

Please let us know if you have any questions. Thank you for supporting the product certification process with the NFSI.

Sincerely,

Russell J. Kendzior
President