



CURECRETE DISTRIBUTION, INC.
dba CURECRETE DISTRIBUTION INTERNATIONAL
dba ADVANCED FLOOR PRODUCTS
1203 SPRING CREEK PLACE SPRINGVILLE, UT 84663 USA
PHN 801.489.5663 FREE 800.998.5664 FAX 801.489.3307
www.curecrete.com

15 April 2021

To Whom It May Concern,

This letter confirms that Curecrete's RetroPlate, a concrete floor densifier, hardener and dustproofing agent, is in compliance with both SCAWMD Rule 1113 and CA Section 01350. The test method used for SCAQMD Rule 1113 is US EPA Method 24 and the VOC Content is reported as "Grams of VOC Per Gram of Material". The test method used for CA Section 01350 is CDPH/EHLB/Standard Method Version 1.2,2017.³

	VOC Content	VOC Emissions
Standard/Rule	SQAMD Rule 1113	CA Section 01350
Test Method	US EPA Method 24	CDPH/EHLB/V1.2,2017.
Category	Adhesives & Sealants	Classroom/Office Scenario
Limit	50g/L	TVOC: <5mg/m ³
Result	0g/L	TVOC: <2µg/m ³
Compliant	YES	YES

Regards,

Dave Hoyt
Vice President of Technical Service
Curecrete Distribution, Inc.



STRIP & PREPARE



FILL & REPAIR



SEAL & STRENGTHEN



STYLE & DESIGN



CLEAN & MAINTAIN